



**NOTES:**

1. ALL SIGNS ARE INDICATED IN THE CONTRACT ITEMS FOR THIS WORK, AND THE FACES ARE TO BE 3M HIGH INTENSITY SHEETING, AS PER MTO STANDARDS OR APPROVED EQUAL.
2. POWER FEED SHALL BE 2 - #10 AWG OR 2 / #8 AWG AS REQUIRED.
3. UNLESS OTHERWISE SPECIFIED ON THE LAYOUT DRAWINGS, BOLLARDS OR SIGNS ARE TO BE CENTERED IN THE MEDIAN AND SET BACK 1500 FROM THE OUTSIDE CURB RADIUS.
4. WITH OPSS FORM 904, CLASS OF CONCRETE TO BE 32 MPa.

ALL DIMENSIONS IN MILLIMETRES  
UNLESS OTHERWISE NOTED



**PUBLIC WORKS  
STANDARD DRAWING**

REV. DATE: DECEMBER 2018

APPROVED BY

DRAWN BY

GK

TSS SECTION

STD. DWG. NUMBER

SCALE

**4-6-1**

N.T.S.

**KEEP RIGHT SIGN  
WITH BEACON**