


NOTES:

1. THIS SCHEMATIC IS INTENDED TO DEPICT THE GENERAL PROCESS FLOW AND LAYOUT OF THE FACILITY. IT IS NOT INTENDED TO DEPICT A COMPLETE DESIGN. REFER TO ADDITIONAL REQUIREMENTS WITHIN THE DESIGN STANDARDS.
2. PROVIDE CONCRETE EMBEDDED CHANNELS FOR TEMPORARY SLIDE PLATE FOR ISOLATION OF SLUICE GATES FOR REPAIR.
3. FORCEMAIN DRAIN THROUGH CHECK VALVES (REVERSE FLOW OPERATOR).
4. PROVIDE MIX FLUSH VALVE ON ONE PUMP OR SUBMERSIBLE WET WELL MIXER.
5. REFER TO ELECTRICAL AND INSTRUMENTATION DRAWINGS FOR ADDITIONAL REQUIRMENTS.

	PUBLIC WORKS STANDARD DRAWING		REV. DATE: APRIL 2021	
	SEWAGE PUMPING STATION TYPE II 20 L/s < RATED CAPACITY <= 60 L/s		APPROVED BY MNB	DRAWN BY GMBluePlan
			STD. DWG. NUMBER SPS-103	SCALE Not to Scale