



NOTES:

1. THIS SCHEMATIC IS INTENDED TO DEPICT THE GENERAL PROCESS FLOW AND LAYOUT OF THE FACILITY. IT IS NOT INTENDED TO DEPICT A COMPLETE DESIGN. REFER TO ADDITIONAL REQUIREMENTS WITHIN THE DESIGN STANDARDS.
2. PROVIDE CONCRETE EMBEDDED CHANNELS FOR TEMPORARY SLIDE PLATE FOR ISOLATION OF SLUICE GATES FOR REPAIR.
3. REFER TO ELECTRICAL AND INSTRUMENTATION DRAWINGS FOR ADDITIONAL REQUIREMENTS.

	PUBLIC WORKS STANDARD DRAWING		REV. DATE: APRIL 2021
	SEWAGE PUMPING STATION TYPE III 60 L/s < RATED CAPACITY <= 500 L/s		APPROVED BY MNB
			DRAWN BY GM BluePlan
			SCALE Not to Scale
			STD. DWG. NUMBER SPS-104