

S.S FLANGED CONNECTION FOR SCREEN REPLACEMENT AND FUTURE CONNECTIONS IF REQUIRED (TYP.)

MIN. 150mm S.S VENT PIPE C/W 180° RETURN AND BIRD/INSECT SCREEN (TYP.)

CLEAN-OUT. SEE STD. DWG. SPS-109

BLIND FLANGE (TYP.)

ACCESS HATCHES SEE STD. DWG SPS-111

NOTE 4

NOTE 3

FINISHED GRADE

1200mm MIN. (TYP.)

1200mm MIN. (TYP.)

300mm MIN.

300mm MIN.

SEE NOTE 2

NOTES:

1. INCLUDE MINIMUM OF 2 VENT PIPES FOR VENTILATION.
2. SUPPLY PIPE EXTENDING TO 0.3m ABOVE OBVERT OF INLET SEWER.
3. FORCED AIR VENTILATOR FOR TYPE III AND IV STATIONS. DO NOT INSTALL AUTO SHUT-OFF DAMPER TO ALLOW NATURAL AIR DRAFT WHEN FAN IS OFF.
4. PROVIDE SEPARATE FLANGED CONNECTION, MIN. 200 mm DIAMETER FOR (FUTURE) ODOUR CONTROL.
5. ALL PIPE MATERIAL ON DRAWING TO BE 316L S.S.
6. ALL WET WELL PENETRATIONS MUST BE SEALED WATER TIGHT.



PUBLIC WORKS
STANDARD DRAWING

REV. DATE: APRIL 2021

APPROVED BY
MNB

DRAWN BY
GM BluePlan

WET WELL VENTILATION AND ACCESSORIES SCHEMATIC

STD. DWG. NUMBER
SPS-110

SCALE
Not to Scale